

Provinces Utilities, Inc. Water System

| Sampling Location | Date Sampled | All results reported as Nanograms per liter(ng/L) | | | | Result Below Health Advisory Level? |
|--------------------|--------------|---|------|----------------------|---------------------------|-------------------------------------|
| | | PFOS | PFOA | Combined PFOS + PFOA | EPA Health Advisory Level | |
| Entry Point Well 2 | 3/31/2020 | ND | ND | ND | 70 | Yes |
| Entry Point Well 3 | 3/31/2020 | ND | ND | ND | 70 | Yes |

- **PFOS** – Perfluorooctane Sulfonate
- **PFOA** – Perfluorooctanoic Acid
- **Health Advisory Level (HAL)** – To provide Americans, including the most sensitive populations, with a margin of protection from a lifetime of exposure to PFOA and PFOS from drinking water, EPA established the health advisory levels at 70 parts per trillion.
- **Ng/L** – Nanograms per liter(ng/L) which equals Parts per trillion (ppt) – One part per trillion corresponds to one minute in 2,000,000 years, or a single penny in \$10,000,000,000.
- **ND (No Detect)** - Laboratory analysis indicates that the constituent is not present. 2.0 ng/L is the minimum level the lab is reporting a detection for these parameters. The ND (No Detect) represented in the table is indicating there was no detection.